

DETAILED ENERGY BALANCE

Data:

Heat capacity:

$$\begin{aligned} \text{C}_3\text{H}_6 &: 2.85 + .23 \times 10^{-2} T - 1.2 \times 10^{-4} T^2 + 2.3 \times 10^{-8} T^3 \text{ (kJ/kmol K)} \\ \text{C}_3\text{H}_4\text{O} &: 3.7957 + 4.4 \times 10^{-2} T - 0.1304 \times 10^{-4} T^2 - 0.2848 \times 10^{-8} T^3 \text{ (cal / mol K)} \\ \text{C}_3\text{H}_4\text{O}_2 &: 1.6828 + 6.9212 \times 10^{-2} T - 0.4475 \times 10^{-4} T^2 + 1.10186 \times 10^{-8} T^3 \text{ (cal / mol K)} \\ \text{C}_2\text{H}_4\text{O}_2 &: 2.0142 + 5.6065 \times 10^{-2} T - 0.3401 \times 10^{-4} T^2 + 0.802 \times 10^{-8} T^3 \text{ (cal / mol K)} \end{aligned}$$

REACTOR I

Heat in:

Feed is preheated to 200°C (molten salt coolant temperature)

$$\begin{aligned} \text{Heat in with C}_3\text{H}_6 &= m \Delta H_{f \text{ at } 25^\circ\text{C}} + m \int_{298}^{473} C_p dT \\ &= 148.38 (20.27 \times 10^3 + \int_{298}^{473} C_p dT) \\ &= 4999350.27 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat in with air} &= m C_p \Delta T \\ \text{(Compressed to 5 bar)} &= 1149.94 \times 1.015 \times 29 \times (200-25) \\ &= 5923484.68 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat in with steam} &= m \lambda + m C_p \Delta T \\ &= 556.42 \times (2676 \times 18 + 2.291 \times 18) \times (200-25) \\ &= 30817126.95 \text{ kJ / hr} \end{aligned}$$

Total heat in = 41739961.9 kJ / hr

Heat Generated :

Heat generated by reaction 1 = 340.8 kJ / mol

Heat generated by reaction 2 = 254.1 kJ / mol

Heat generated by other side reactions are neglected.

$$\begin{aligned} \text{Total heat generated} &= 340.8 \times 10^3 \times 103.866 + 254.1 \times 10^3 \times 16.32 \\ &= \mathbf{39544444.8 \text{ kJ / hr}} \end{aligned}$$

Heat removed by Coolant :

The temperature in the reactor reaches an average peak temperature of 355°C due to the exothermic reaction.

At the end of the catalyst bed, the temperature drops toward that of molten salt coolant (210°C).

$$\begin{aligned}\text{Heat with acrolein} &= m \int_{628}^{483} C_p dT \\ &= 103.866 \times \int_{628}^{483} C_p dT \\ &= 1493068.88 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with Acrylic acid} &= m \int_{628}^{483} C_p dT \\ &= 16.32 \times \int_{628}^{483} C_p dT \\ &= 278848.6 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with Acetic acid} &= m \int_{628}^{483} C_p dT \\ &= 14.096 \times \int_{628}^{483} C_p dT \\ &= 205053.1 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with air} &= m C_p \Delta T \\ &= 1001.55 \times 30.35 \times (628-483) \\ &= 4408195.62 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with CO}_2 &= m C_p \Delta T \\ &= 14.096 \times 47.896 \times (628-483) \\ &= 97897.62 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with steam} &= m C_p \Delta T \\ &= 660.286 \times 36.173 \times (628-483) \\ &= 3463347.34 \text{ kJ / hr}\end{aligned}$$

Total heat removed by the Coolant = 9946411.17 kJ/hr

Heat out:

$$\begin{aligned}\text{Heat out with Acrolein} &= m \int_{483}^{298} C_p dT \\ &= 103.866 m \int_{628}^{298} C_p dT \\ &= 1509276.32\end{aligned}$$

$$\begin{aligned}\text{Heat with Acrylic acid} &= m \int_{483}^{298} C_p dT \\ &= 16.32 \times \int_{483}^{298} C_p dT \\ &= 283613.82 \text{ kJ/hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with Acetic acid} &= m \int_{483}^{298} C_p dT \\ &= 14.096 \times \int_{483}^{298} C_p dT \\ &= 208578.2 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with air} &= m C_p \Delta T \\ &= 1001.55 \times 30.35 \times (483-298) \\ &= 5624249.59 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with CO}_2 &= m C_p \Delta T \\ &= 14.096 \times 42.37 \times (483-298) \\ &= 110490.79 \text{ kJ / hr}\end{aligned}$$

$$\begin{aligned}\text{Heat with steam} &= m C_p \Delta T \\ &= 660.286 \times 33.913 \times (483-298) \\ &= 4142581.4 \text{ kJ / hr}\end{aligned}$$

Total heat out = 11878790.12 kJ/hr

Heat to Waste heat boiler

$$\begin{aligned} &= \text{Heat in} + \text{Heat generated} - \text{Heat removed by coolant} - \text{Heat out} \\ &= 59459205.41 \text{ kJ/hr} \end{aligned}$$

$$\begin{aligned} \text{Water required in boiler} = m &= 59459205.41 / \lambda \\ &= 22219.43 \text{ kg/hr} \end{aligned}$$

REACTOR II

$$\text{Heat in from reactor I} = 11878790.12 \text{ kJ/hr}$$

Heat generated:

$$\begin{aligned} &= 254.1 \times 10^3 \text{ kJ/kmol of Acrylic acid} \\ &= 254.1 \times 10^3 \times 101.26 \\ &= \mathbf{25730166 \text{ kJ/hr}} \end{aligned}$$

Heat removed by coolant:

The feed to the second reactor enters at temperature of 210°C.

The temperature in the reactor reaches an average peak temperature of 300°C due to the exothermic reaction.

At the end of the catalyst bed, the temperature drops toward that of molten salt coolant (210°C).

$$\begin{aligned} \text{Heat with Acrylic acid} &= m \int_{210}^{300} C_p dT \\ &= 117.58 \times \int_{210}^{300} C_p dT \\ &= 1211152.08 \text{ kJ / hr} \end{aligned}$$

$$\text{Heat with Acetic acid} = m \int_{210}^{300} C_p dT$$

483

$$= 15.3942 \times \int_{573}^{298} C_p dT$$

$$= 134946.92 \text{ kJ / hr}$$

Heat with air

$$= m C_p \Delta T$$

$$= 949.617 \times 30.35 \times (573-483)$$

$$= 2588415.83 \text{ kJ / hr}$$

Heat with CO₂

$$= m C_p \Delta T$$

$$= 15.3942 \times 46.0548 \times (573-483)$$

$$= 63807.91 \text{ kJ / hr}$$

Heat with steam

$$= m C_p \Delta T$$

$$= 660.286 \times 35.42 \times (573-483)$$

$$= 2104879.2 \text{ kJ / hr}$$

Total heat removed by the Coolant = 6103201.95 kJ/hr

Heat out:

Heat with Acrylic acid

$$= m \int_{483}^{298} C_p dT$$

$$= 117.58 \times \int_{483}^{298} C_p dT$$

$$= 2043343.9 \text{ kJ / hr}$$

Heat with Acetic acid

$$= m \int_{483}^{298} C_p dT$$

$$= 15.3942 \times \int_{483}^{298} C_p dT$$

$$= 54442.55 \text{ kJ / hr}$$

Heat with air

$$= m C_p \Delta T$$

$$= 949.617 \times 30.35 \times (483-298)$$

$$= 5332617.47 \text{ kJ / hr}$$

Heat with CO₂

$$= m C_p \Delta T$$

$$= 15.3942 \times 40.528 \times (483-298)$$

$$= 115421.42 \text{ kJ / hr}$$

$$\begin{aligned}
 \text{Heat with steam} &= m C_p \Delta T \\
 &= 660.286 \times 36.913 \times (483-298) \\
 &= 4142581.4 \text{ kJ / hr}
 \end{aligned}$$

Total heat out = 11861751.85 kJ/hr.

Heat to Waste heat boiler

$$\begin{aligned}
 &= \text{Heat in} + \text{Heat generated} - \text{Heat removed by coolant} - \text{Heat out} \\
 &= 19644022.32 \text{ kJ/hr}
 \end{aligned}$$

$$\begin{aligned}
 \text{Water required in boiler} = m &= 19644022.32 / \lambda \\
 &= 7340.8 \text{ kg/hr}
 \end{aligned}$$

ABSORBER:

Heat in:

Heat in from the second reactor = 11861751.85 kJ/hr

Absorbing solvent water enters at 30°C.

$$\begin{aligned}
 \text{Heat in with water} &= m C_p \Delta T \\
 &= 488.6 \times 4.186 \times 18 \times (30-25) \\
 &= \mathbf{184075.1 \text{ kJ/hr}}
 \end{aligned}$$

Total heat in = 10317508.86 kJ/hr

Heat out along with the offgas:

The off gas leave the column at 70°C

$$\begin{aligned}
 \text{Heat with Acrylic acid} &= m \int_{343}^{298} C_p dT \\
 &= 1.1758 \times \int_{343}^{298} C_p dT \\
 &= 4344.66 \text{ kJ / hr}
 \end{aligned}$$

$$\begin{aligned}
 \text{Heat with Acetic acid} &= m \int_{343}^{298} C_p dT \\
 &= 0.1539 \times \int_{343}^{298} C_p dT
 \end{aligned}$$

$$= 485.04 \text{ kJ / hr}$$

$$\begin{aligned} \text{Heat with air} &= m C_p \Delta T \\ &= 949.617 \times 30.35 \times (343-298) \\ &= 1297110.34 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat with CO}_2 &= m C_p \Delta T \\ &= 15.3942 \times 40.52 \times (343-298) \\ &= 28075.48 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat with water} &= m C_p \Delta T \\ &= 66.0286 \times 33.913 \times (343-298) \\ &= 100764.5 \text{ kJ / hr} \end{aligned}$$

Total heat out with the off gas= 1430780.02 kJ/hr.

Heat out along with the bottom product:

The bottom products leave the column at 80°C.

$$\begin{aligned} \text{Heat with Acrylic acid} &= m \int_{353}^{298} C_p dT \\ &= 116.404 \times \int_{353}^{298} C_p dT \\ &= 531493.66 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat with Acetic acid} &= m \int_{353}^{298} C_p dT \\ &= 15.396 \times \int_{353}^{298} C_p dT \\ &= 61021.65 \text{ kJ / hr} \end{aligned}$$

$$\begin{aligned} \text{Heat with water} &= m C_p \Delta T \\ &= 1082.85 \times 4.186 \times 18 \times (343-298) \\ &= 4487481.99 \text{ kJ / hr} \end{aligned}$$

Total heat out with the bottom product = 5079997.3 kJ/hr.

Heat to inter stage cooler (Minor equipment)

=Heat in - Heat out with off gas - Heat out at the bottom

= **5535049.54 kJ/hr**